



GÖLFHITASKRÁ (DEILIKISTA #2)

SLAUFAR NR.	c/c [mm]	AFKÖST [W/m ²]	l [m]	STÆRD [m ²]	AFKÖST [W]	q [l/min]	HITASTIGÍ RÝMI [°C]	HITANEMI Í RÝMI	OPNUN STILLILOKA
201	100	73,6	76,0	7,6	559	1,16	20	T1	100%
202	100	73,6	72,0	7,2	530	1,10	20	T1	74%
203	100	73,6	66,0	6,6	486	1,00	20	T1	68%
204	100	73,6	61,0	6,1	449	0,93	20	T1	63%
205	100	73,6	61,0	6,1	449	0,93	20	T1	63%
206	100	73,6	71,0	7,1	523	1,08	20	T1	73%
207	100	73,6	67,0	6,7	493	1,02	20	T1	69%
208	100	73,6	62,0	6,2	456	0,94	20	T1	64%
209	100	73,6	60,0	6	442	0,91	20	T1	62%
210	100	73,6	65,0	6,5	478	0,99	20	T1	67%
211	100	73,6	62,0	6,2	456	0,94	20	T1	64%
SAMTALS			723 m		5,3 kW	11,00 l/min			

GÖLFHITASKRÁ (DEILIKISTA #5)

SLAUFAR NR.	c/c [mm]	AFKÖST [W/m ²]	l [m]	STÆRD [m ²]	AFKÖST [W]	q [l/min]	HITASTIGÍ RÝMI [°C]	HITANEMI Í RÝMI	OPNUN STILLILOKA
101	200	57,6	87,0	17,4	1002	2,07	20	T1	100%
102	200	57,6	55,0	11	634	1,31	20	T1	55%
103	200	57,6	65,0	13	749	1,55	20	T1	68%
104	200	57,6	71,0	14,2	818	1,69	20	T2	77%
105	150	65,0	53,0	7,95	517	1,07	20	T2	37%
106	100	100,0	51,0	5,1	510	1,05	20	T3	36%
107	100	100,0	40,0	4	400	0,83	20	T4	28%
108	200	57,6	66,0	13,2	760	1,57	20	T4	70%
109	200	57,6	70,0	14	806	1,67	20	T4	75%
110	200	57,6	70,0	14	806	1,67	20	T5	75%
SAMTALS			628 m		7,0 kW	14,48 l/min			

GÖLFHITASKRÁ (DEILIKISTA #6)

SLAUFAR NR.	c/c [mm]	AFKÖST [W/m ²]	l [m]	STÆRD [m ²]	AFKÖST [W]	q [l/min]	HITASTIGÍ RÝMI [°C]	HITANEMI Í RÝMI	OPNUN STILLILOKA
101	150	86,4	97,0	14,55	1257	2,60	22	T1	100%
102	150	86,4	96,0	14,4	1244	2,57	22	T1	99%
103	150	86,4	87,0	13,05	1128	2,33	22	T1	87%
104	150	86,4	92,0	13,8	1192	2,47	22	T1	93%
105	100	100,0	90,0	9	900	1,86	22	T1	72%
106	100	100,0	92,0	9,2	920	1,90	22	T1	74%
107	100	100,0	90,0	9	900	1,86	22	T1	72%
108	100	100,0	96,0	9,6	960	1,99	22	T1	79%
SAMTALS			740 m		8,5 kW	17,58 l/min			

ARITUN ADALHÖNNUDAR: *Fl. G. S. S. S.* KT. *Ólafur S.*

BR.	DAGS.	BREYTING	SAMP.



HVÍTÁRBRAUT 19 ÖLFUSSI
FRÍSTUNÐARHÚS
GÓLHITI
GRUNNMÝND 1. HÆÐ

SAMPYKKT: _____ KT. _____

HÖNNUÐUR	YFIRFARID	DAGS. ÚTG.	DAGS. BREYT.
GP	gummi@ferill.is	HÞV	25.02.13
MKV.	VERKNR.	TEIKN. NR.	BREYT.
1:50	12101	3-102	

Ferill ehf. Mörkin 1 108 Reykjavík Sími: 575 1600 Fax: 575 1601 www.ferill.is